

HONOLULU FIRE DEPARTMENT  
**CITY AND COUNTY OF HONOLULU**

638 South Street  
Honolulu, Hawaii 96813-5007  
Phone: 808-723-7139 Fax: 808-723-7111 Internet: www.honolulu.gov/hfd

MUFI HANNEMANN  
MAYOR



KENNETH G. SILVA  
FIRE CHIEF

ALVIN K. TOMITA  
DEPUTY FIRE CHIEF

November 28, 2008

TO: WAYNE YOSHIOKA, DIRECTOR  
DEPARTMENT OF TRANSPORTATION SERVICES

FROM: KENNETH G. SILVA, FIRE CHIEF

SUBJECT: HONOLULU HIGH-CAPACITY TRANSIT CORRIDOR PROJECT  
DRAFT ENVIRONMENTAL IMPACT STATEMENT

In response to your letter of November 12, 2008, regarding the above-mentioned subject, the Honolulu Fire Department (HFD) reviewed the material provided and requires that the following be complied with:

1. Provide a fire apparatus access road for every facility, building, or portion of a building hereafter constructed or moved into or within the jurisdiction when any portion of the facility or any portion of an exterior wall of the first story of the building is located more than 150 feet (45 720 mm) from a fire apparatus access road as measured by an approved route around the exterior of the building or facility. (1997 Uniform Fire Code, Section 902.2.1.)
2. Provide a water supply, approved by the county, capable of supplying the required fire flow for fire protection to all premises upon which facilities or buildings, or portions thereof, are hereafter constructed or moved into or within the county.

On-site fire hydrants and mains capable of supplying the required fire flow shall be provided when any portion of the facility or building is in excess of the 150 feet (45 720 mm) from a water supply on a fire apparatus access road, as measured by an approved route around the exterior of the facility or building. (1997 Uniform Fire Code, Section 903.2, as amended.)

3. Submit civil drawings to the HFD for review and approval.

DIRECTOR'S OFFICE  
DEPARTMENT OF  
TRANSPORTATION SERVICES

08 DEC 2 11:11

RECEIVED

Wayne Yoshioka, Director

Page 2

November 28, 2008

Should you have any questions, please call Battalion Chief Socrates Bratakos of our Fire Prevention Bureau at 723-7151.



KENNETH G. SILVA

Fire Chief

KGS/SY:jl

cc: Ted Matley, FTA Region IX