


LINDA LINGLE
GOVERNOR



STATE OF HAWAII
DEPARTMENT OF TRANSPORTATION
869 PUNCHBOWL STREET
HONOLULU, HAWAII 96813-5097

August 4, 2010

SSFM INTERNATIONAL, INC.
RECEIVED
AUG 11 2010
Jkc
FILE

BRENNON T. MORIOKA
DIRECTOR

Deputy Directors
MICHAEL D. FORMBY
FRANCIS PAUL KEENO
BRIAN H. SEKIGUCHI
JIRO A. SUMADA

IN REPLY REFER TO:

STP 8.0180

Mr. Jared K. Chang
Project Planner
SSFM International
501 Sumner Street, Suite 620
Honolulu, Hawaii 96817

FILE COPY

Dear Mr. Chang:

Subject: Kalaeloa Precast Yard – Pre-Assessment Consultation for
Draft Environmental Assessment (DEA)

Thank you for requesting the State Department of Transportation's (DOT) review of the subject project, which proposes to use a 34-acre parcel to serve as a Precast Yard to fabricate precast concrete elements for the West Oahu/Farrington Highway Guideway segment of the Honolulu High-Capacity Transit Corridor Project. While the subject project is located on lands owned by the Department of Hawaiian Home Lands, jurisdiction of the redevelopment belongs to the Hawaii Community Development Authority. Access to the project is through San Juancinto Street off the intersection of Coral Sea Road and adjacent to the Kalaeloa Airport-John Rodgers Field.

Given the project location, DOT's nearby airport (Kalaeloa Airport) and highways facilities (Coral Sea Road) will be impacted. DOT offers the following comments regarding potential impacts to the State airport:

1. The subject project is located in flight path of the Kalaeloa Airport. The DEA should confirm that any structures built at this site will not penetrate this approach zone air space of Kalaeloa Airport.
2. Because of the close proximity of the facility to Kalaeloa Airfield, DOT recommends that the applicant file Federal Aviation Administration (FAA) Form 7460-1: Notice of Proposed Construction or Alteration. This is the website for filing FAA Form 7460-1: <https://www.oaava.faa.gov/oaava/external/portal.jsp>.

The DOT Highways Division is concluding its review of the subject project for impacts to DOT highway facilities. Upon completion of this review, DOT will provide additional comments as necessary.

Mr. Jared K. Chang
Page 2
August 4, 2010

STP 8.0180

DOT appreciates the opportunity to provide comments. If there are any questions, please contact Mr. David Shimokawa of the DOT Statewide Transportation Planning Office at telephone number (808) 587-2356.

Very truly yours,

A handwritten signature in black ink, appearing to read 'BM', with a horizontal line extending to the right.

BRENNON T. MORIOKA, Ph.D., P.E.
Director of Transportation